

## CERTIFICATE OF ANALYSIS

A3G1318

Commodore Perry High School

Jarrod Breese 3002 Perry HWY Hadley, PA 16130 Project Name: SemiAnnual DEP Lead & Copper (20

SAMPLES)

Project / PO Number: N/A Received: 07/14/2023 Reported: 07/25/2023

**Project Special Information** 

6430300

COMMODORE PERRY SCHOOL

**Analytical Testing Parameters** 

Client Sample ID:

Sample Matrix:

**Drinking Water** 

Site 700 Superintendant Drinking Fountain

Collected By:

Client

Lab Sample ID:

A3G1318-02

**Collection Date:** 

07/05/2023 7:30

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Copper	0.0125	1.3	0.000400	mg/L		07/18/23 1352	07/18/23 1352	SEA
Lead	<0.000400	0.015	0.000400	mg/L		07/18/23 1352	07/18/23 1352	SEA

Client Sample ID:

Site 701 Girls Locker Room Drinking Fountain

Sample Matrix:

**Drinking Water** 

Lab Sample ID: A3G1318-03 Collected By: **Collection Date:**  Client

07/05/2023 8:20

Analyst RL Units Note Prepared Analyzed Limit(s) Metals Total by ICPMS Result Method: EPA 200.8, Rv. 5.4 (1994) 07/20/23 1802 SEA 0.127 1.3 0.00200 mg/L 07/20/23 1802 Copper 07/18/23 1402 07/18/23 1402 SEA mg/L < 0.000400 0.015 0.000400 Lead

Client Sample ID:

Site 702 Boys Locker Room Drinking Fountain

Sample Matrix: Lab Sample ID: **Drinking Water** 

A3G1318-04

Collected By: **Collection Date:**  Client

07/05/2023 8:30

Analyst Analyzed Prepared Metals Total by ICPMS Result Limit(s) RL Units Note Method: EPA 200.8, Rv. 5.4 (1994) 07/18/23 1405 SEA mg/L 07/18/23 1405 0.000400 0.0840 1.3 Copper 07/18/23 1405 07/18/23 1405 SEA < 0.000400 0.015 0.000400 mg/L Lead



# **CERTIFICATE OF ANALYSIS**

# A3G1318

			AJGT	510					
Client Sample ID: Sample Matrix: Lab Sample ID:	Site 703 Elem 1st FI Dr Drinking Water A3G1318-05	inking Fountain				Collected By: Collection Date:	Client 07/05/2	2023 7:45	
Metals Total by ICPMS	3	Result	Limit(s)	RL	Units	Note Pro	epared	Analyzed	Analys
Method: EPA 200.8, R	v. 5.4 (1994)								
Copper		0.0968	1.3	0.000400	mg/L		/23 1407	07/18/23 1407	SEA
Lead		0.000469	0.015	0.000400	mg/L	07/18	/23 1407	07/18/23 1407	SEA
Client Sample ID: Sample Matrix:	Site 704 Elem 2nd Fl D Drinking Water	rinking Fountain	Andrew Control of the	. M. das Assistanting Address Statistics and Materials	New your production of the second	Collected By:	Client	والمراجع والم والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع والمراج	
Lab Sample ID:	A3G1318-06					Collection Date:	07/05/2	2023 7:40	
Metals Total by ICPMS	5	Result	Limit(s)	RL	Units	Note Pro	epared	Analyzed	Analys
Method: EPA 200.8, R									
Copper		0.0352	1.3	0.000400	mg/L		/23 1410	07/18/23 1410	SEA
Lead		<0.000400	0.015	0.000400	mg/L	07/18	/23 1410	07/18/23 1410	SEA
Client Sample ID:	Site 705 HS Lobby Drin	king Fountain	a programme and the second	anayanan sanganangi 1925 an	management same over ye	Velocities - An industrial to the NOVIII can destroy a service of the Noviet Control of	A Trickly designed.	and a state of the	
Sample Matrix:	Drinking Water					Collected By:	Client		
Lab Sample ID:	A3G1318-07					Collection Date:	07/05/2	2023 8:10	
Metals Total by ICPMS	C . Harmonia magnific A Addition, and demonstrate and desired in the second	Result	Limit(s)	RL	Units	Note Pro	epared	Analyzed	Analys
Method: EPA 200.8, R	v. 5.4 (1994)								
Copper		0.0331	1.3	0.000400	mg/L		/23 1413	07/18/23 1413	SEA
Lead		<0.000400	0.015	0.000400	mg/L	07/18	/23 1413	07/18/23 1413	SEA
Client Sample ID:	Site 706 HS Athletics S	ink Tap		· · · · · · · · · · · · · · · · · · ·	· Commence of the second secon	C. H. M. Dur	Client		
Sample Matrix:	Drinking Water					Collected By:		2023 8:15	
Lab Sample ID:	A3G1318-08				MANUAL CONTRACTOR	Collection Date:	07/05/2	ZUZ3 8:15	

Limit(s)

1.3

0.015

0.000400

0.000400

Units

mg/L

mg/L

Note

Prepared

07/18/23 1415 07/18/23 1415

07/18/23 1415 07/18/23 1415

Result

0.0561

<0.000400

Metals Total by ICPMS

Copper

Lead

Method: EPA 200.8, Rv. 5.4 (1994)

Analyzed

Analyst

SEA



# CERTIFICATE OF ANALYSIS

#### A3G1318

Client Sample ID:

Site 707 Nurses Suite Sink Tap

Sample Matrix:

Drinking Water

Lab Sample ID:

A3G1318-09

Collected By:

**Collection Date:** 

Client

07/05/2023 7:55

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)	معلم المسلم			, , , , , , , , , , , , , , , , , , ,				
Copper	0.120	1.3	0.00200	mg/L		07/20/23 1805	07/20/23 1805	SEA
Lead	0.000817	0.015	0.000400	mg/L		07/18/23 1418	07/18/23 1418	SEA

Client Sample ID:

Site 708 Middle School 1st Fl Drinking Fountain

Sample Matrix:

**Drinking Water** 

A3G1318-10 Lab Sample ID:

Collected By:

Client

**Collection Date:** 

07/05/2023 7:35

Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
0.0118	1.3	0.000400	mg/L		07/18/23 1420	07/18/23 1420	SEA
0.000400	0.015	0.000400	mg/L		07/18/23 1420	07/18/23 1420	SEA
	0.0118	0.0118 1.3	0.0118 1.3 0.000400	0.0118 1.3 0.000400 mg/L	0.0118 1.3 0.000400 mg/L	0.0118 1.3 0.000400 mg/L 07/18/23 1420	0.0118 1.3 0.000400 mg/L 07/18/23 1420 07/18/23 1420

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

**Definitions** 

mg/L:

Milligrams per Liter

RL:

Reporting Limit

#### Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division

02-00257

Pennsylvania Department of Environmental Protection

### **Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <a href="https://www.microbac.com/standard-terms-conditions">https://www.microbac.com/standard-terms-conditions</a>.

Reviewed and Approved By:

Carolyn M. Vollentine

Carolyn Vollentine

Service Center Manager Reported: 07/25/2023 15:42

Microbac Laboratories Inc., Pittsburgh Division 100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | www.microbac.com

Page 3 of 17



## CERTIFICATE OF ANALYSIS

A3G4451

**Commodore Perry High School** 

Jarrod Breese 3002 Perry HWY Hadley, PA 16130 Project Name: Resample DEP Lead/Copper

Project / PO Number: N/A Received: 08/01/2023 Reported: 08/07/2023

**Project Special Information** 

6430300

COMMODORE PERRY SCHOOL

**Analytical Testing Parameters** 

Client Sample ID: Site 80

Site 801 Cafeteria Sink Tap

Sample Matrix: Lab Sample ID: Drinking Water A3G4451-01 Collected By:

Jarrod Breese

Collection Date:

07/31/2023 8:00

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Copper	0.0645	1.3	0.000400	mg/L		08/04/23 1527	08/04/23 1527	SEV
Lead	0.0140	0.015	0.000400	mg/L		08/04/23 1527	08/04/23 1527	SEV

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

**Definitions** 

mg/L:

Milligrams per Liter

RL:

Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division

02-00257

Pennsylvania Department of Environmental Protection

### **Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <a href="https://www.microbac.com/standard-terms-conditions">https://www.microbac.com/standard-terms-conditions</a>.

Reviewed and Approved By:

arolyn M. Vollentine

Carolyn Vollentine Service Center Manager Reported: 08/07/2023 15:26

Microbac Laboratories Inc., Pittsburgh Division

100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | www.microbac.com

Page 1 of 3